



Lehi City Storm Water Drainage Master Plan

Approved by the Lehi City Council on May 12, 2015

Scale: 1:12,000



See Traverse Mountain Area Plan

See Micron Area Plan

Outflow = 0.07 CFS / Acre (Or Less)

Outflow = 0.13 CFS / Acre (Or Less)

Outflow = 0.10 CFS / Acre (Or Less)

Legend

- Existing Sumps
- Storm Drain Manholes
- Storm Drain Outlets
- Storm Drain Lines
- Existing Ditches

Future Storm Drain Lines

Type

- Existing Irrigation Drainage to be Altered
- Proposed Drainage Facility
- Future Detention Basins
- Existing Detention Basins

