



Lehi Fire Department

Home Business Self Inspection Form



This form is to be completed by the business owner/representative. All the information contained in this form is considered applicable unless otherwise specified.

Business Name:

Business Address:

Business Owner:

Phone Number:

Requirements

- | | | |
|------------------------------|---|---|
| <input type="checkbox"/> | Address | Is your address placed in a position that is plainly visible from the street or road fronting the property? Address shall be a minimum of 4" in height. |
| <input type="checkbox"/> | Smoke/CO Detectors | At least one smoke detector is required on each level of the home and one in each bedroom. One CO or combination CO/smoke detector is required. Detectors should be tested monthly and batteries replaced annually. |
| <input type="checkbox"/> | Fire Extinguishers | One 5lb accessible fire extinguisher "2A10BC" rated is required. Extinguisher is required to have an annual inspection and must be tagged by a certified service technician. Extinguisher must be mounted or secured to a wall. |
| <input type="checkbox"/> | Exits/Hallways | All exit hallways, doorways, stairways, landings, and walkways must be clear of any obstructions. |
| <input type="checkbox"/> | Storage | Maintain 36" clearance around all electrical panels, furnace, water heater or any Fuel-fired appliances. |
| <input type="checkbox"/> | Electrical | Extension cords cannot be used in place of permanent wiring. Power strips cannot be plugged into another power strip. No open slots in electrical panel allowed. All receptacles and switches should have approved covers installed. |
| N/A <input type="checkbox"/> | <input type="checkbox"/> Hazardous Materials | Do you use and/or store any hazardous materials? Do you use and/or store any flammable combustible liquids in large quantities? (If you answer yes to either of these questions a fire department inspection is required, contact the fire department to schedule). |

I hereby certify that the information is true and correct to the best of my knowledge.

Printed Name:

Signature:

Date: