



NOTES:

1. IF ACCESSIBLE TO TRUCK TRAFFIC, TO OTHER VEHICLES OVER 8' IN HEIGHT, OR TO RIDERS ON HORSEBACK, MINIMUM ATTACHMENT HEIGHT IS 16'; REFER TO NESC TABLE 232-1.
2. IF THE SERVICE IS CROSSING THE ROOF FOR MORE THAN 6' HORIZONTALLY IN ANY DIRECTION, OR MORE THAN 4' HORIZONTALLY FROM THE NEAREST EDGE OF THE ROOF, REFER TO NESC 234C3 FOR THE APPROPRIATE CLEARANCE:
3. FOR CLEARANCE OF SERVICE DROPS, SEE SECTION 230 OF THE NESC.
4. SERVICE MAST MUST BE MOUNTED ON SIDE NEAREST POLE, LEHI CITY POWER & BUILDING INSPECTION TO APPROVE LOCATION.
5. LEHI CITY POWER DEPARTMENT INSPECTION REQUIRED PRIOR TO CONNECTION.
6. USE OXIDE INHIBITOR WHEN TERMINATING ALUMINUM CONDUCTORS.



**REQUIREMENTS & STANDARDS
OVERHEAD SERVICE
100-400 AMP (1 PHASE)
RESIDENTIAL POWER SERVICE**

DWG: **3.2.5**

REV. 0.00

BY: GWK/BT

DATE: 3/16/17