

DRAWING: LPRS-DWG-05.3-2017

MANDREL TABLE	
CONDUIT (NOM.) DIAMETER	MANDREL DIAMETER
3"	2.5"
4"	3.5"
6"	5.5"

* HDPE REQUIRES A SMALLER DIAMETER MANDREL - USE ONE THAT PROOFS 80% OF THE NOMINAL DIAMETER.



REQUIREMENTS & STANDARDS
MANDREL TABLE

RESIDENTIAL & COMMERCIAL POWER SERVICE

DWG: **4.2.4**

REV. 17.00

BY: EB/

DATE: 01/5/19