



NOTES:

1. CLEARANCE REQUIRED ACCORDING TO NEC 450.27.
2. ADDITIONAL CLEARANCES MAY BE REQUIRED BY APPLICABLE LOCAL AND STATE BUILDING CODES.



REQUIREMENTS & STANDARDS

CLEARANCE TO

COMBUSTIBLE STRUCTURES

FROM TRANSFORMERS

(LOCATED IN THE P.U.E.)

DWG: 5.3
REV. 0.00
BY: GWK/BT
DATE: 12/12/17