



NOTES:

1. WIRE SIZE RANGE: LUGS SUITABLE FOR #2 - 350 kcmil Cu/Al CONDUCTORS.
2. APPROXIMATE DIMENSIONS: 5"(D) x 13"(W) x 19"(H).
3. METER SOCKET SHALL HAVE BYPASS. (LINK OR MANUAL)
4. KNOCKOUTS: THREE ON BOTTOM AND ONE EACH ON BOTH SIDES AND BACK; KNOCKOUTS ARE CONCENTRIC TYPE WITH A MAXIMUM DIAMETER OF 3".
5. FOR OVERHEAD SERVICES, METER SOCKETS ARE FURNISHED WITH A HUB SIZED AS NEEDED; AVAILABLE HUB SIZES ARE 1-1/4", 1-1/2", 2" AND 2-1/2".



REQUIREMENTS & STANDARDS
METER SOCKET UP TO 400 AMP
WIRING DIAGRAM
3 WIRE WYE 3 PHASE
120/240 OR 277/480 VOLT
(7 TERMINAL SOCKET W/ LINK BY-PASS)

DWG: **6.1.3**

REV. 0.00

BY: GWK/BT

DATE: 3/30/17

DRAWING: LEHICITY_DWG061317-2017