



NOTES:

1. EUSERC APPROVED CT CABINET & METER BASE SHALL BE SEALABLE & LOCKABLE BY LEHI CITY POWER.
2. MAIN SERVICE DISCONNECT IS REQUIRED OUTSIDE AT THE METER LOCATION
3. INSTALLATION LOCATION SHALL BE APPROVED BY LEHI CITY POWER DEPT.
4. CONDUIT CLAMPS MUST BE ABOVE GROUND.
5. CONTRACTOR SHALL SUPPLY AND TERMINATE SECONDARY CONDUCTORS AT TRANSFORMER.
6. INSPECTION REQUIRED PRIOR TO BACK FILL OF TRENCH. REFER TO 4.2.1
7. INSPECTION REQUIRED PRIOR TO PERMANENT POWER CONNECTION.
8. OWNER/BUILDER SHALL SUPPLY AND INSTALL PER NEC REQUIREMENTS AND MAINTAIN CONDUIT AND CONDUCTORS FROM THE CT ENCLOSURE TO THE POWER SOURCE SUPPLIED BY LEHI CITY POWER.



**REQUIREMENTS & STANDARDS**  
**CT CABINET INSTALLATION**  
**SERVICES 800 AMP MAXIMUM**

**COMMERCIAL 1 PHASE POWER SERVICE**

DWG: **6.2.3**

REV. 0.00

BY: GWK/BT

DATE: 3/28/17

DRAWING LEGS: EUSERC 11-10-17